



Village of  
Elmwood Park

Peter N. Silvestri  
Village President  
Elsie Sutter  
Village Clerk  
John J. Dalicandro  
Village Manager  
Michael Durkin  
Village Attorney

**Trustees**  
Alan L. Bennett  
Sam LaBarbera  
Carmen P. Forte  
Alan T. Kaminski  
Jeff Sargent  
Angela Stranges

November 22, 2011

Mr. Harry L. Parker  
2038 N. 77<sup>th</sup> Ct.  
Elmwood Park, Il. 60707

Dear Mr. Parker:

The Village of Elmwood Park (the "Village") is in receipt of your November 22, 2011 Freedom of Information Act (5 ILCS 140/1 *et. seq.*) ("FOIA") request for the following records:

"Copy of the building permit that includes the permit for a new roof installed October 2001 and the inspection report."

Enclosed please find a 2001 Building Permit and Inspection/Complaint Form issued by the Code Administrative Department.

The Village of Elmwood Park maintains no other documents responsive to your request.

Sincerely,

Elsie Sutter  
Freedom of Information Officer  
Enclosures

# 2001 BUILDING PERMITS

Permit No	Recd Date	Issue Date	Paid Date	Property Description	Pin No
11118	8/22/200	08/27/01	8/29/2001	single family	12-36-112-054

Owners Last Name	Owners First Name	Phone	
Kessler			Blue Prints Only

Property Address	City	State	Zip Cod
2038 N. 77th Ct.	Elmwood Park	IL	60707

Contractor	Job Description	Census
La Mantia Const.	addition&master bedrm. ext.	434-res/additons/alterations/c

Valuation	Permit Fee	Electrical	Elec Per No	Elec Val	Elec Per Fee	C/O Uni	C/O Unit A Date
83,700.00	855.00		01-234	5,000.00	103.00		

Plmb	Plmbg Permit No	Plmbg Val	Plmbg Permit Fee	C/O Single Famil	C/O Uni	C/O Unit B Date
<input checked="" type="checkbox"/>	11118	3,000.00	50.00			

HVAC	HVAC Permit	HVAC Valuation	HVAC Permit Fee	C/O Uni	C/O Unit C Date
<input checked="" type="checkbox"/>	11118	3,500.00	55.00		

Insp Date	Insp Resul	Insp Pass Date	Inspector	C/O Uni	C/O Unit D Date

**Insp Remarks**

09/07/01: Footing insp. MLP. Footing approved per Bob.

10/10/01: prep work insp/bsmnt flr/Bob. DM

10/30/01: plmbg,elec,hvac&frmng/Ralph,Joe&Bob. DM

Electric:Tub:relocate motor junction box. exhaust fan dischrg to roof exhaust vent.1st flr fam rm:add outlet east wall phones per Joe & Doug. DM Plmbg: OK rough work per Ralph. DM

11/01/01:Elect. Inspt. 200 amp serv/ Village will call Com Ed. called in per Joe 11/2/01. JS

C/O Uni	C/O Unit E Date
C/O Uni	C/O Unit F Date
C/O Uni	C/O Unit G Date
C/O Uni	C/O Unit H Date
C/O Uni	C/O Unit I Date

# CODE ADMINISTRATION INSPECTION/COMPLAINT FORM

INSPECTION DATE

11/01/01

INSP TIME

10:30

CALL IN DATE:

10/31/01

ADDRESS

2038 N. 77th Ct.

INSPECTOR

Joe/Ralph/Bob

OWNER

Kessler #11118

PHONE

[REDACTED]

CONTRACTOR

LaMantia Constr. #01-234

CONT. PHONE

[REDACTED]

ROUGH

FINAL

BUSINESS

PREPOUR

FRAMING

HVAC

PLMBG

ELECTRICAL

PASS

PASS

PASS

PASS

PASS

FAIL

FAIL

FAIL

FAIL

FAIL

COMPLAINT

INSPECTION

COMPLAINT INFO

10/30/01: Plmbg, elec, frmng & hvac/Ralph,Joe&Bob. DM

11/01/01: Elec inspt/Joe. JS

04/25/02: Final elec,plmbg&frmng/addition&master bdrm/Bob&Ralph.DM

04/29/02: Final inspt, elec & frmng, addition. OJ

INSP COMPLAINT FINDING

10/30/01:Elec:Tub:relocate motor junctn bx,exhaust fan dischrq to roof exhaust vent,1st flr fam.rm: add outlet east wall, telephones/Joe&doug agreemnt.Plmbg:ok rough wrk/Ralph.DM 11/01/01:Called ComEd 200 amp overhead chng&addition apprvd. 4/29/02:All wrk apprvd/Bob. OJ