



village of  
**Elmwood Park**

Peter N. Silvestri  
Village President  
Elsie Sutter  
Village Clerk  
John J. Dalicandro  
Village Manager  
Michael Durkin  
Village Attorney

**Trustees**  
Alan L. Bennett  
Sam LaBarbera  
Carmen P. Forte  
Alan T. Kaminski  
Jeff Sargent  
Angela Stranges

September 1, 2011

Mr. Lou Thao  
2799 Wells Fargo Way  
Minneapolis, Minnesota 55467

Re: German Vazquez  
7738 West Sunset  
Elmwood Park, Illinois 60707

Dear Sir:

I am in receipt of your Freedom of Information Act (5ILCS 140/1 et. seq.) (hereinafter referred to as "FOIA) request, which was received by the Village of Elmwood Park August 31, 2011 for the following public records:

"Please provide a print out of inspection history/record on the property for the permit that was issued on 12-09-2010. "

Enclosed herewith please find documents responsive to your request.

Sincerely,

Elsie Sutter  
Freedom of Information Officer

FAXED TO: 877-719-0879

0879

# Building Permits Inspection Schedule



Village of  
Elmwood Park

By: r:ojones  
09/01/2011 - 1:53 PM

Scheduled Date and Time Inspector Contact Information	Address	Permit No	Inspection Type	Appr. Comp.	
11/18/2010 10:00 Robert Bormann	7738 SUNSET DR Bldg & Misc. ( ) -	000000101677	Pre-Permit Inspt.	no	yes
Notes: Discussed project w/owner/Bob oj					
12/13/2010 10:30 Robert Bormann	7738 SUNSET DR Bldg & Misc. ( ) -	000000101677	Footing	yes	yes
Notes: Apprvd to pour footings. Bob/gp					
12/15/2010 12:22 Inspector	7738 SUNSET DR Plumbg Inspt (847) 490-1443	000000101677	Complaint	no	yes
Notes: Contractor urinating in rear yard, nghbr very upset.oj- Called general contractor/Kamil about his worker, informed him that either his workers need access to bthrm or a portajohn, nghbr is stating next time police will be called, Kamil will spk to all his workers about this prblm, .oj					
12/20/2010 11:00 Robert Bormann	7738 SUNSET DR Bldg & Misc. ( ) -	000000101677	FramingInspt	yes	yes
Notes: Floor framing apprvd. Bob/gp					
04/28/2011 10:00 Robert Bormann	7738 SUNSET DR Bldg & Misc. ( ) -	000000101677	FramingRough	no	no
Notes: and hvac.-Cancelled by homeowner, will reschedule. gp					
07/05/2011 11:00 Jim Guenther	7738 SUNSET DR Elec & Misc. ( ) -	000000101677	Elec Rough	no	no
Notes: remrk Bx,check grnd for servc Jim/dg					
07/05/2011 11:00 Jim Guenther	7738 SUNSET DR Elec & Misc. ( ) -	000000101677	Plmbg Rough	no	no
Notes: elec rough not done No disc for dshwshr,smke in east bedrm needs to be moved jim/dg					

Scheduled Date and Time Inspector Contact Information	Address	Permit No	Inspection Type	Appr.	Comp.
--	---------	-----------	-----------------	-------	-------

08/03/2011 10:00 Robert Bormann	7738 SUNSET DR Bldg & Misc. ( ) -	000000101677	Insulation	no	no
------------------------------------	--------------------------------------	--------------	------------	----	----

Notes:

Firestop not placed, struts to basement & 2nd floor not Code, risers are different heights, insulation not approved, Batts are cut short in wall & ceiling./Bob oj

08/05/2011 01:30 Jim Guenther	7738 SUNSET DR Elec & Misc. ( ) -	000000101677	Insulation/2nd inspt	no	no
----------------------------------	--------------------------------------	--------------	----------------------	----	----

Notes:

Approved to drywall./Bob oj

# Building Permits Inspection Schedule

er: ojones

09/01/2011 - 2:02 PM



Village of  
Elmwood Park

Scheduled Date and Time Inspector Contact Information	Address	Permit No	Inspection Type	Appr. Comp.
--	---------	-----------	-----------------	-------------

07/05/2011 11:00 Jim Guenther Elec & Misc. ( ) -	7738 SUNSET DR
---	----------------

000000102039	Elec Rough	no	no
--------------	------------	----	----

**Notes:**

Remrk BX check grnd for service./Jim dg

# Building Permits Inspection Schedule

er: ojones

09/01/2011 - 1:56 PM



Village of  
Elmwood Park

Scheduled Date and Time Inspector Contact Information	Address	Permit No	Inspection Type	Appr. Comp.
--	---------	-----------	-----------------	-------------

07/05/2011 10:00 Inspector Plumbg Inspt (847) 490-1443	7738 SUNSET DR	000000102040	Plmbg Rough	no no
---	----------------	--------------	-------------	-------

### Notes:

1. Provide proper support, for all pvc drains & vents as per IPC (every 4')  
2. Provide proper pitch on all drains (whirlpool tub)  
3. complete bsmt plmbg,  
4. complete ktchn drain & vent,  
5. Provide proper vent to bsmt plmbg, drain tile aprvd only, may bckfill/ Jeff/B&F Tech. dm