

Village of
Elmwood Park



Angelo "Skip" Saviano
Village President
Gina Pesko
Village Clerk
Paul A. Volpe
Village Manager
Michael Durkin
Village Attorney

Trustees
Alan T. Kaminski
Jeff Sargent
Angela Stranges
Anthony Del Santo
Angelo J. Lollino
Jonathan L. Zivojnovic

FREEDOM OF INFORMATION
REQUEST FOR PUBLIC RECORDS

Freedom of Information Officers:

Gina Pesko
Village Clerk

Paul A. Volpe
Village Manager
Village of Elmwood Park
11 Conti Parkway
Elmwood Park, IL. 60707

From: Anne Rezulak
(Name - Please print)

2208 North 76th Avenue
(Address)

Elmwood Park, Illinois 60707
(City, State and Zip)

Cell No's 1-224-500-8105 or
(Telephone) 312-415-2423

DESCRIPTION OF REQUESTED RECORD(S)

House inspection done by ^{code Dept,} Jerry & Commander
Kleese, and a gentleman ^(Blackhair wavy + black glasses) from the fire dept. It was
a inspection from the Homeowner ^{of Jeffrey Miller,}
Inspection done later part of January 2015 or first week of Feb.
2015

Please indicate if you wish to inspect the above captioned records or wish a copy of them.

Inspection Copy Both

Do you wish to have copies certified? Yes No


There is no charge for reproducing the first fifty copies. Over fifty 15 cents each.

Certified copies \$1.00 each

Copies can be picked up at 11 Conti Parkway, Elmwood Park, Illinois or mailed..

Date Received Friday 2/13/2015

Date Response Due



2/13: Sent mail to BKlog for his report.



Village of
Elmwood Park

11 Conti Parkway Elmwood Park, IL 60707
1-708-452-3920

Rental Inspection
Narrative Report

DATE: 1/30/2015

OWNER(S) NAME: Jeff Miller Phone: 773-771-1111

ADDRESS: 2208 N 76th Ave.

ZONING DIST: R-1

Number of Units: 1-SFH

Agent: Phone:

Fax:

Email:

Smoke Alarms:

- Smoke alarm installation required "INSIDE" each sleeping room.
- Smoke alarm installation required main floor living area.
- Smoke alarm installation required in Furnace/utility area.

Carbon Monoxide Detector:

- Required within 15ft of any sleeping area.

Electrical:

- All kitchen counter receptacles shall have tamper-proof GFCI protection.
- Laundry area shall contain at least one (1) tamper-proof GFCI receptacle.
- Cover any open electrical boxes.
- Cover plates required on all countertop and wall receptacles
- Electrical panel shall have all circuits properly identified, labeled, numbered, and affixed to the panel's cover.

Hot Water Tank:

- Temperature-Pressure-Relief Valve (TPR) discharge pipe shall be of rigid metal piping, properly installed, and maintained on all water heaters.


Jerry Alport

Code Enforcement Officer
Village of Elmwood Park
Code Administration Department