



Village of
Elmwood Park

Angelo "Skip" Saviano
Village President
Gina Pesko
Village Clerk
Paul A. Volpe
Village Manager
Michael Durkin
Village Attorney

Trustees
Alan T. Kaminski
Jeff Sargent
Angela Stranges
Anthony Del Santo
Angelo J. Lollino
Jonathan L. Zivojnovic

Mr. Suleiman Aqel
2718 N. 76th Ct
Elmwood Park, IL 60707

January 20, 2016

RE: Freedom of Information Act Request

Dear Mr. Aqel

The Village of Elmwood Park is in receipt of your January 19, 2016, Freedom of Information Act (5 ILCS 140/1 et seq.) ("FOIA") for the following records:

"...copy of violations this add: 2816 72nd Court."

Enclosed are records responsive to your request. However, please be advised that certain information in the records being provided has been determined to be exempt from disclosure under FOIA, and that information has been redacted from the records being provided.

Section 7 (1)(b) of FOIA provides that "private information" is exempt from disclosure. "Private information" is defined in FOIA as, "unique identifiers, including a person's social security number, driver's license number, employee id number, biometric identifiers, personal financial information, passwords or other access codes, medical records, home or personal telephone numbers, and personal email addresses." Section 7(1)(c) of FOIA provides that, "personal information contained within public records, the disclosure of which would constitute a clearly unwarranted invasion of personal privacy is exempt from disclosure. Consequently, birthdates and other personal information, the disclosure of which would constitute a clearly unwarranted invasion of personal privacy, such as the victim's name and identifying information, have been redacted from the records being provided.

In accordance with Section 9(a) of FOIA, you are hereby notified that you have the right to file a Request for Review regarding the decision made by the Village of Elmwood Park Freedom of Information Officer with the Public Access Counselor at the Illinois Attorney General's Office.

You can file your Request for Review with the Public Access Counselor by writing to:

Sarah Pratt
Public Access Counselor
Office of the Attorney General
500 South 2nd Street
Springfield, Illinois 62706
Fax: 217-782-1396
E-mail: publicaccess@atg.state.il.us

If you choose to file a Request for Review with the Public Access Counselor, you must do so within 60 calendar days of the date of this letter. Please note that you must include a copy of your original FOIA request and this letter when filing a Request for Review with the Public Access Counselor. You are also notified that you have the right to judicial review regarding the decision made by the Village of Elmwood Park Freedom of Information Officer pursuant to Section II of FOIA.

Should you have any questions, please do not hesitate to contact my office.

Gina Pesko

Village Clerk
Freedom of Information Officer
708-452-3948

LISTING INSPECTION COMMENT SHEET

ADDRESS: 2816 72 Ct.

12/11/2015

Zone: R -1 Units: 1

1. Chimney needs a rain cap.
2. Scrape and repaint peeling surfaces.
3. Handrails needed on all stairs with returns to the wall.
4. This is a single family residence – basement kitchen to be de-converted and front entrance removed.
5. Covered fixtures needed in all closets.
6. Possible roof leak – fix problem is any
Repair damaged gutters and downspouts.
7. Rats in garage to be exterminated
Mold in basement to be remediated.
8. Replace cracked/broken sidewalks
Parking pad next to garage broken-up – to be removed .
9. Smoke/CO detectors needed (see handout).
10. Water meter has been disconnected – contact Water Dept.
Evidence of leaks from 1st floor bathroom – find and fix issues
Visible incorrect in-wall plumbing to be corrected – possibly more violations within walls.
11. Garage in dilapidated condition – to be demolished.
12. Electrical service needs an outside ground rod.

13. Remove BX/Romex and put into conduit.
14. Tamperproof GFI outlets in all wet locations and grounded outlets throughout
15. Cover open electrical boxes
Eliminate extension cords.
16. Furnace and water heater may not be operational
Water heater needs a metal overflow pipe.
17. All windows to be operable, crack-free and have insect screens
18. Whole rear yard covered with concrete and blocks – blocks/pavers to be removed to allow water drainage.

.....