



Village of
Elmwood Park

Angelo "Skip" Saviano
Village President
Gina Pesko
Village Clerk
Paul A. Volpe
Village Manager
Michael Durkin
Village Attorney

Trustees
Alan T. Kaminski
Jeff Sargent
Angela Stranges
Anthony Del Santo
Angelo J. Lollino
Jonathan L. Zivojnovic

Mr. Ryan Hoff
ETS Environmental & Associates

November 19, 2019

RE: Freedom of Information Act Request

Dear Mr. Hoff,

The Village of Elmwood Park is in receipt of your November 18, 2019, Freedom of Information Act (5 ILCS 140/1 et seq.) ("FOIA") for the following records:

"7943 West Grand Avenue...any underground storage tank (UST), above ground storage tank (AST) , emergency spill responses, or other pertinent Department information"

Attached are records responsive to your request. There is no evidence of any underground or above ground tanks at this property.

Should you have any questions, please do not hesitate to contact my office.

Sincerely,

Gina Pesko, Village Clerk
Freedom of Information Officer
Village of Elmwood Park
708-452-3948

Johnson Tools Notes 6-27-14

	Inc.	Alarm	Avail	Location	Incident Type	UNITS
1					Open wires, loose extension boards	
2						
3				Northwest corner	Structural issues with roof/wall	
4						
5				North east corner	Hot water heater should have B-vent	
6						
7					Hanging electrical throughout	
8						
9				North east entrance	Red tank possible flammable liquid hanging from ceiling	✓
10						
11					Hole in wall above north entrance	
12						
13					Missing exit signs	
14						
15					Lots of clutter throughout	✓
16						
17				Southwest Quad part	improper ventilation kiln	✓
18						
19						
20						
21						
22						
23						
24						

Johnson Tools Notes 6-27-14

	Inc.	Alarm	Avail	Location	Incident Type	UNITS
1				NW corner shop	Furnace vent removed AC running thru roof	2
2				Front office	extension cords under duct tape	
3				SW corner shop	pallet and cardboard storage	cardboard drums
4				SW corner shop	oily metal	55 gallon drum
5				SW corner shop	multiple liquid filled open containers	
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						

CODE ADMINISTRATION INSPECTION/COMPLAINT FORM

Prompt

INSPECTION DATE

6/27/14, Fri

INSP TIME

10:00

CALL IN DATE:

6/24/14 JA

ADDRESS

7943 Bane

INSPECTOR

B-7 el

OWNER

Johnson Lane

PHONE

PERMIT NO.

CONTRACTOR

CONT. PHONE

ROUGH

FINAL

BUSINESS

PREPOUR

FRAMING

HVAC

PLMBG

ELECTRICAL

PASS

PASS

PASS

PASS

PASS

FAIL

FAIL

FAIL

FAIL

FAIL

Jim Al

COMPLAINT INSPECTION

INFORMATION:

See report

FINDINGS:

- Ground xformer
- No extension cords
- Close-up any open J-Boxes w/open knock-outs
- EXIT SIGNS - NON-OPERABLE
- open conductors of J-Box in bead room TO LIGHT
- open SPLICES
- un-supported outlets fed w/FMC

Jim Al

POSTED

CODE ADMINISTRATION INSPECTION/COMPLAINT FORM

Prompt

INSPECTION DATE: 6/25/14, Tue INSP TIME: 10:00 CALL IN DATE: 6/24/14 JA

ADDRESS: 7943 Grand INSPECTOR: B. F. Pluney

OWNER: Johnson Joel PHONE: _____ PERMIT NO.: _____

CONTRACTOR: _____ CONT. PHONE: _____

ROUGH FINAL BUSINESS

PREPOUR FRAMING HVAC PLMBG ELECTRICAL

PASS PASS PASS PASS PASS

FAIL FAIL FAIL FAIL FAIL

COMPLAINT INSPECTION

[Signature]

INFORMATION:

Pluney Inspt

[Signature]

FINDINGS:

① Remove TUB S Shower.

② Provide HOT WATER @ All Sinks. No less than 110°F

POSTED